



Standard Method of SALT SPRAY (FOG) TESTING¹

This Standard is issued under the fixed designation B 117; the number immediately following the designation indicates the year of original adoption or, in the case of revision, the year of last revision. A number in parentheses indicates the year of last reapproval.

This method has been approved by the Department of Defense to replace method 811.1 of Federal Test Method Standard No. 151b and for listing in DoD Index of Specifications and Standards. Future proposed revisions should be coordinated with the Federal Government through the Army Materials and Mechanics Research Center, Watertown, Mass. 02172.

1. Scope

1.1 This method sets forth the conditions required in salt spray (fog) testing for specification purposes. Suitable apparatus which may be used to obtain these conditions is described in Appendix A1. The method does *not* prescribe the type of test specimen or exposure periods to be used for a specific product, nor the interpretation to be given to the results. Comments on the use of the test in research will be found in Appendix A2.

NOTE 1—This method is applicable to salt spray (fog) testing of ferrous and non-ferrous metals, and is also used to test inorganic and organic coatings, etc., especially where such tests are the basis for material or product specifications.

2. Apparatus

2.1 The apparatus required for salt spray (fog) testing consists of a fog chamber, a salt solution reservoir, a supply of suitably conditioned compressed air, one or more atomizing nozzles, specimen supports, provision for heating the chamber, and necessary means of control. The size and detailed construction of the apparatus are optional, provided the conditions obtained meet the requirements of this method.

2.2 Drops of solution which accumulate on the ceiling or cover of the chamber shall not be permitted to fall on the specimens being tested.

2.3 Drops of solution which fall from the specimens shall not be returned to the solution reservoir for respraying.

2.4 Material of construction shall be such that it will not affect the corrosiveness of the fog.

3. Test Specimens

3.1 The type and number of test specimens to be used, as well as the criteria for the evaluation of the test results, shall be defined in the specifications covering the material or product being tested or shall be mutually agreed upon by the purchaser and the seller.

4. Preparation of Test Specimens

4.1 Metallic and metallic-coated specimens shall be suitably cleaned. The cleaning method shall be optional depending on the nature of the surface and the contaminants, except that it shall not include the use of abrasives other than a paste of pure magnesium oxide nor of solvents which are corrosive or will deposit either corrosive or protective films. The use of a nitric acid solution for the chemical cleaning, or passivation, of stainless steel specimens is permissible when agreed upon by the purchaser and the seller. Care shall be taken that specimens are not recontaminated after cleaning by excessive or careless handling.

4.2 Specimens for evaluation of paints and other organic coatings shall be prepared in accordance with applicable specification(s) for the material(s) being tested, or as agreed upon by the purchaser and supplier. Otherwise, the test specimens shall consist of steel meeting the requirements of ASTM Methods D 609 for Preparation of Steel Panels for Testing

¹ This method is under the jurisdiction of ASTM Committee G-1 on Corrosion of Metals, and is the direct responsibility of Subcommittee G01.05 on Laboratory Corrosion Tests.

Current edition approved March 29, 1973. Published June 1973. Originally published as B 117 - 39 T. Last previous edition B 117 - 64.

Paint, Varnish, Lacquer, and Related Products,² and shall be cleaned and prepared for coating in accordance with applicable procedure of Method D 609.

4.3 Specimens coated with paints or nonmetallic coatings shall not be cleaned or handled excessively prior to test.

4.4 Whenever it is desired to determine the development of corrosion from an abraded area in the paint or organic coating, a scratch or scribed line shall be made through the coating with a sharp instrument so as to expose the underlying metal before testing. The conditions of making the scratch shall be as defined in ASTM Method D 1654, Evaluation of Painted or Coated Specimens Subjected to Corrosive Environments,² unless otherwise agreed upon between the purchaser and seller.

4.5 Unless otherwise specified, the cut edges of plated, coated, or duplex materials and areas containing identification marks or in contact with the racks or supports shall be protected with a suitable coating stable under the conditions of the test, such as ceresin wax.

NOTE 2—Should it be desirable to cut test specimens from parts or from preplated, painted, or otherwise coated steel sheet, the cut edges shall be protected by coating them with paint, wax, tape, or other effective media so that the development of a galvanic effect between such edges and the adjacent plated or otherwise coated metal surfaces, is prevented.

5. Position of Specimens During Test

5.1 The position of the specimens in the salt spray chamber during the test shall be such that the following conditions are met:

5.1.1 Unless otherwise specified, the specimens shall be supported or suspended between 15 and 30 deg from the vertical and preferably parallel to the principal direction of horizontal flow of fog through the chamber, based upon the dominant surface being tested.

5.1.2 The specimens shall not contact each other or any metallic material or any material capable of acting as a wick.

5.1.3 Each specimen shall be so placed as to permit free settling of fog on all specimens.

5.1.4 Salt solution from one specimen shall not drip on any other specimen.

NOTE 3—Suitable materials for the construction or coating of racks and supports are glass, rubber, plastic, or suitably coated wood. Bare metal shall not be used. Specimens shall preferably be supported from the bottom or the side. Slotted wooden

strips are suitable for the support of flat panels. Suspension from glass hooks or waxed string may be used as long as the specified position of the specimens is obtained, if necessary by means of secondary support at the bottom of the specimens.

6. Salt Solution

6.1 The salt solution shall be prepared by dissolving 5 ± 1 parts by weight of sodium chloride in 95 parts of distilled water or water containing not more than 200 ppm of total solids. The salt used shall be sodium chloride substantially free of nickel and copper and containing on the dry basis not more than 0.1 percent of sodium iodide and not more than 0.3 percent of total impurities. Some salts contain additives that may act as corrosion inhibitors; careful attention should be given to the chemical content of the salt. By agreement between purchaser and seller, analysis may be required and limits established for elements or compounds not specified in the chemical composition given above.

6.2 The pH of the salt solution shall be such that when atomized at 35 C (95 F) the collected solution will be in the pH range of 6.5 to 7.2 (Note 4). Before the solution is atomized it shall be free of suspended solids (Note 5). The pH measurement shall be made electrometrically at 25 C (77 F) using a glass electrode with a saturated potassium chloride bridge in accordance with Method E 70, Test for pH of Aqueous Solutions with the Glass Electrode³; or colorimetrically using bromothymol blue as indicator, or short range pH paper which reads in 0.2 or 0.3 of a pH unit (Note 6).

NOTE 4—Temperature affects the pH of a salt solution prepared from water saturated with carbon dioxide at room temperature and pH adjustment may be made by the following three methods:

(1) When the pH of a salt solution is adjusted at room temperature, and atomized at 35 C (95 F), the pH of the collected solution will be higher than the original solution due to the loss of carbon dioxide at the higher temperature. When the pH of the salt solution is adjusted at room temperature, it is therefore necessary to adjust it below 6.5 so the collected solution after atomizing at 35 C (95 F) will meet the pH limits of 6.5 to 7.2. Take about a 50-ml sample of the salt solution as prepared at room temperature, boil gently for 30 s, cool, and determine the pH. When the pH of the salt solution is adjusted to 6.5 to 7.2 by this procedure, the pH of the atomized and collected solution at 35 C (95 F) will come within this range.

² 1974 Annual Book of ASTM Standards, Part 27.

³ 1973 Annual Book of ASTM Standards, Parts 16, 22, 30.

(2) Heating the salt solution to boiling and cooling to 95 F or maintaining it at 95 F for approximately 48 h before adjusting the pH produces a solution the pH of which does not materially change when atomized at 35 C (95 F).

(3) Heating the water from which the salt solution is prepared to 35 C (95 F) or above, to expel carbon dioxide, and adjusting the pH of the salt solution within the limits of 6.5 to 7.2 produces a solution the pH of which does not materially change when atomized at 35 C (95 F).

NOTE 5—The freshly prepared salt solution may be filtered or decanted before it is placed in the reservoir, or the end of the tube leading from the solution to the atomizer may be covered with a double layer of cheesecloth to prevent plugging of the nozzle.

NOTE 6—The pH can be adjusted by additions of dilute cp hydrochloric acid or cp sodium hydroxide solutions.

7. Air Supply

7.1 The compressed air supply to the nozzle or nozzles for atomizing the salt solution shall be free of oil and dirt (Note 7) and maintained between 69 and 172 kN/m² (10 and 25 psi) (Note 8).

NOTE 7—The air supply may be freed from oil and dirt by passing it through a water scrubber or at least 610 mm (2 ft) of suitable cleaning material such as asbestos, sheep's wool, excelsior, slag wool, or activated⁴ alumina.

NOTE 8—Atomizing nozzles may have a "critical pressure" at which an abnormal increase in the corrosiveness of the salt fog occurs. If the "critical pressure" of a nozzle has not been established with certainty, control of fluctuation in the air pressure within plus or minus 0.7 kN/m² (0.1 psi), by installation of a suitable pressure regulator valve⁵ minimizes the possibility that the nozzle will be operated at its "critical pressure."⁶

8. Conditions in the Salt Spray Chamber

8.1 *Temperature*—The exposure zone of the salt spray chamber shall be maintained at 35 + 1.1 – 1.7 C (95 + 2 – 3 F). The temperature within the exposure zone of the closed cabinet shall be recorded at least twice a day at least 7 h apart (except on Saturdays, Sundays, and holidays when the salt spray test is not interrupted for exposing, rearranging, or removing test specimens or to check and replenish the solution in the reservoir).

NOTE 9—A suitable method to record the temperature is by a continuous recording device or by a thermometer which can be read from outside the closed cabinet. The recorded temperature must be obtained with the salt spray chamber closed to avoid a false low reading because of wet-bulb effect when the chamber is open.

8.2 *Atomization and Quantity of Fog*—At least two clean fog collectors shall be so

placed within the exposure zone that no drops of solution from the test specimens or any other source shall be collected. The collectors shall be placed in the proximity of the test specimens, one nearest to any nozzle and the other farthest from all nozzles. The fog shall be such that for each 80 cm² of horizontal collecting area there will be collected in each collector from 1.0 to 2.0 ml of solution per hour based on an average run of at least 16 h (Note 10). The sodium chloride concentration of the collected solution shall be 5 ± 1 weight percent (Note 11). The pH of the collected solution shall be 6.5 to 7.2. The pH measurement shall be made electrometrically or colorimetrically using bromothymol blue as the indicator.

NOTE 10—Suitable collecting devices are glass funnels with the stems inserted through stoppers into graduated cylinders, or crystallizing dishes. Funnels and dishes with a diameter of 10 cm have an area of about 80 cm².

NOTE 11—A solution having a specific gravity of 1.0255 to 1.0400 at 25 C (77 F) will meet the concentration requirement. The concentration may also be determined as follows: Dilute 5 ml of the collected solution to 100 ml with distilled water and mix thoroughly; pipet a 10-ml aliquot into an evaporating dish or casserole; add 40 ml of distilled water and 1 ml of 1 percent potassium chromate solution (chloride-free) and titrate with 0.1 N silver nitrate solution to the first appearance of a permanent red coloration. A solution that requires between 3.4 and 5.1 ml of 0.1 N silver nitrate solution will meet the concentration requirements.

8.3 The nozzle or nozzles shall be so directed or baffled that none of the spray can impinge directly on the test specimens.

9. Continuity of Test

9.1 Unless otherwise specified in the specifications covering the material or product being tested, the test shall be continuous for the duration of the entire test period. Continuous operation implies that the chamber be

⁴ Registered U. S. Patent Office.

⁵ The Nullmatic pressure regulator (or equivalent) manufactured by Moore Products Co., H and Lycoming Sts., Philadelphia, Pa. 19124, is suitable for this purpose.

⁶ It has been observed that periodic fluctuations in air pressure of ±3.4 kN/m² (0.5 psi) resulted in about a two-fold increase in the corrosivity of the fog from a nozzle which was being operated at an average pressure of 110 kN/m² (16 psi). Controlling the fluctuations within ±0.7 kN/m² (0.1 psi), however, avoided any increase in the corrosivity of the salt fog. See Darsey, V. M. and Cavanagh, W. R., "Apparatus and Factors in Salt Fog Testing," *Proceedings, ASTEA, Am. Soc. Testing Mats.*, Vol. 48, 1948, p. 153.

closed and the spray operating continuously except for the short daily interruptions necessary to inspect, rearrange, or remove test specimens; to check and replenish the solution in the reservoir, and to make necessary recordings as described in Section 8. Operations shall be so scheduled that these interruptions are held to a minimum.

10. Period of Test

10.1 The period of test shall be as designated by the specifications covering the material or product being tested or as mutually agreed upon by the purchaser and the seller.

NOTE 12—Recommended exposure periods are to be as agreed upon by the purchaser and seller, but exposure periods of multiples of 24 h are suggested.

11. Cleaning of Tested Specimens

11.1 Unless otherwise specified in the specifications covering the material or product being tested, specimens shall be treated as follows at the end of the test:

11.1.1 The specimens shall be carefully removed.

11.1.2 Specimens may be gently washed or dipped in clean running water not warmer than 38 C (100 F) to remove salt deposits from their surface, and then immediately dried. Drying shall be accomplished with a stream of clean, compressed air.

12. Evaluation of Results

12.1 A careful and immediate examination shall be made for the extent of corrosion of the dry test specimens or for other failure as required by the specifications covering the

material or product being tested or by agreement between the purchaser and the seller.

13. Records and Reports

13.1 The following information shall be recorded, unless otherwise prescribed in the specifications covering the material or product being tested:

13.1.1 Type of salt and water used in preparing the salt solution,

13.1.2 All readings of temperature within the exposure zone of the chamber,

13.1.3 Daily records of data obtained from each fog-collecting device including the following:

13.1.3.1 Volume of salt solution collected in milliliters per hour per 80 cm²,

13.1.3.2 Concentration or specific gravity at 35 C (95 F) of solution collected, and

13.1.3.3 pH of collected solution.

13.4 Type of specimen and its dimensions, or number or description of part,

13.5 Method of cleaning specimens before and after testing,

13.6 Method of supporting or suspending article in the salt spray chamber,

13.7 Description of protection used as required in 4.5,

13.8 Exposure period,

13.9 Interruptions in test, cause and length of time, and

13.10 Results of all inspections.

NOTE 13—If any of the atomized salt solution which has not contacted the test specimens is returned to the reservoir, it is advisable to record the concentration or specific gravity of this solution also.

APPENDIXES

A1. CONSTRUCTION OF APPARATUS

A1.1 Cabinets

A1.1.1 Standard salt-spray cabinets are available from several suppliers, but certain pertinent accessories are required before they will function according to this method and provide consistent control for duplication of results.

A1.1.2 The salt spray cabinet consists of the basic chamber, an air-saturator tower, a salt solution reservoir, atomizing nozzles, specimen supports, provisions for heating the chamber, and suitable controls for maintaining the desired tempera-

ture.

A1.1.3 Accessories such as a suitable adjustable baffle or central fog tower, automatic level control for the salt reservoir, and automatic level control for the air-saturator tower are pertinent parts of the apparatus.

A1.1.4 The cabinet should be of sufficient size to test adequately the desired number of parts without overcrowding. Small cabinets have been found difficult to control and those of less than 0.43-m³ (15-ft³) capacity should be avoided.

A1.1.5 The chamber may be made of inert materials such as plastic, glass, or stone, but most preferably is constructed of metal and lined with impervious plastics, rubber, or epoxy-type materials or equivalent.

A1.2 Temperature Control

A1.2.1 The maintenance of temperature within the salt chamber can be accomplished by several methods. It is generally desirable to control the temperature of the surroundings of the salt spray chamber and to maintain it as stable as possible. This may be accomplished by placing the apparatus in a constant-temperature room, but may also be achieved by surrounding the basic chamber of a jacket containing water or air at a controlled temperature.

A1.2.2 The use of immersion heaters in an internal salt-solution reservoir or of heaters within the chamber is detrimental where heat losses are appreciable, because of solution evaporation and radiant heat on the specimens.

A1.2.3 All piping which contacts the salt solution or spray should be of inert materials such as plastic. Vent piping should be of sufficient size so that a minimum of back pressure exists and should be installed so that no solution is trapped. The exposed end of the vent pipe should be shielded from extreme air currents that may cause fluctuation of pressure or vacuum in the cabinet.

A1.3 Spray Nozzles

A1.3.1 Satisfactory nozzles may be made of hard rubber, plastic, or other inert materials. The most commonly used type is made of plastic. Nozzles calibrated for air consumption and solution atomized are available. The operating characteristics of a typical nozzle are given in Table A1.

A1.3.2 It can readily be seen that air consumption is relatively stable at the pressures normally used, but a marked reduction in solution sprayed occurs if the level of the solution is allowed to drop appreciably during the test. Thus, the level of the solution in the salt reservoir must be maintained automatically to ensure uniform fog delivery during the test.⁷

A1.3.3 If the nozzle selected does not atomize the salt solution into uniform droplets, it will be necessary to direct the spray at a baffle or wall to pick up the larger drops and prevent them from impinging on the test specimens. Pending a complete understanding of air-pressure effects, etc., it is important that the nozzle selected shall produce the desired condition when operated at the air pressure

selected. Nozzles are not necessarily located at one end, but may be placed in the center and can also be directed vertically up through a suitable tower.

A1.4 Air for Atomization

A1.4.1 The air used for atomization must be free of grease, oil, and dirt before use by passing through well-maintained filters. Room air may be compressed, heated, humidified, and washed in a water-sealed rotary pump, if the temperature of the water is suitably controlled. Otherwise cleaned air may be introduced into the bottom of a tower filled with water, through a porous stone or multiple nozzles. The level of the water must be maintained automatically to ensure adequate humidification. A chamber operated according to this method and Appendix will have a relative humidity between 95 and 98 percent. Since salt solutions from 2 to 6 percent will give the same results (though for uniformity the limits are set at 4 to 6 percent), it is preferable to saturate the air at temperatures well above the chamber temperature as insurance of a wet fog. Table A2 shows the temperatures, at different pressures, that are required to offset the cooling effect of expansion to atmospheric pressure.

A1.4.2 Experience has shown that most uniform spray chamber atmospheres are obtained by increasing the atomizing air temperature sufficiently to offset heat losses, except those that can be replaced otherwise at very low-temperature gradients.

A1.5 Types of Construction

A1.5.1 A modern laboratory cabinet is shown in Fig. A1. Walk-in chambers are not usually constructed with a sloping ceiling due to their size and location. Suitably located and directed spray nozzles avoid ceiling accumulation and drip. Nozzles may be located at the ceiling, or 0.91 m (3 ft) from the floor directed upward at 30 to 60 deg over a passageway. The number of nozzles depends on type and capacity and is related to the area of the test space. A 11 to 19-dm³ (3 to 5-gal) reservoir is required within the chamber, with the level controlled. The major features of a walk-in type cabinet, which differs significantly from the laboratory type, are illustrated in Fig. A2. Construction of a plastic nozzle, such as is furnished by several suppliers, is shown in Fig. A3.

⁷ A suitable device for maintaining the level of liquid in, either the saturator tower, or reservoir of test solution may be designed by a local engineering group, or may be purchased from manufacturers of test cabinets as an accessory.

A2. USE OF THE SALT SPRAY (FOG) TEST IN RESEARCH

A2.1 The detailed requirements of this method are primarily for quality acceptance and should not be construed as the optimum conditions for research studies. The test has been used to a considerable extent for the purpose of comparing different materials or finishes with an acceptable standard. The recent elimination of many cabinet variables and the improvement in controls have made the three

ASTM Salt Spray Tests: Method B 117, Method B 287, Acetic Acid-Salt Spray (Fog) Testing,^{2, 8} and Method B 368, for Copper-Accelerated Acetic Acid-Salt Spray (Fog) Testing (CASS),^{2, 8} into useful tools for many industrial and military production

⁸ 1973 Annual Book of ASTM Standards, Part 7.



and qualification programs.

A2.2 The test has been used to a considerable extent for the purpose of comparing different materials or finishes. It should be noted that there is seldom a direct relation between salt spray (fog) resistance and resistance to corrosion in other media, because the chemistry of the reactions, including the formation of films and their protective value, frequently varies greatly with the precise conditions encountered. Informed personnel are aware of the erratic composition of basic alloys, the possibility of wide variations in quality and thickness of plated items produced on the same racks at the same time, and the consequent need for a mathematical determination of the number of specimens required to constitute an adequate sample for test purposes. In this connection it is well to point out that Method B 117 is not applicable to the study or testing of decorative chromium plate (nickel-chromium or copper-nickel-chromium) on steel or on zinc-base die castings or of cadmium plate on steel. For this purpose Methods B 287 and B 368 are available, which are also considered by some to be superior for comparison of chemically-treated aluminum

(chromated, phosphated, or anodized), although final conclusions regarding the validity of test results related to service experience have not been reached. Method B 117 is considered to be most useful in estimating the relative behavior of closely related materials in marine atmospheres, since it simulates the basic conditions with some acceleration due to either wetness or temperature or both.

A2.3 When a test is used for research, it may prove advantageous to operate with a different solution composition or concentration or at a different temperature. In all cases, however, it is desirable to control the temperature and humidity in the manner specified, and to make certain that the composition of the settled fog and that of the solution in the reservoir are substantially the same. Where differences develop, it is necessary to control conditions so that the characteristics of the settled fog meet the specified requirements for the atmosphere.

A2.4 Material specifications should always be written in terms of the standard requirements of the appropriate salt-spray method, thereby making it possible to test a variety of materials from different sources in the same equipment.

TABLE A1 Operating Characteristics
of Typical Spray Nozzle


Siphon Height, in.	Air Flow, liters/min				Solution Consumption, ml/h			
	Air Pressure, psi				Air Pressure, psi			
	5	10	15	20	5	10	15	20
4	19	26.5	31.5	36	2100	3840	4584	5256
8	19	26.5	31.5	36	636	2760	3720	4320
12	19	26.5	31.5	36	0	1380	3000	3710
16	19	26.6	31.5	36	0	780	2124	2904

Siphon Height cm	Air Flow, dm ³ /min				Solution Consumption, cm ³ /h			
	Air Pressure, kN/m ²				Air Pressure, kN/m ²			
	34	69	103	138	34	69	103	138
10	19	26.5	31.5	36	2100	3840	4584	5256
20	19	26.5	31.5	36	636	2760	3720	4320
30	19	26.5	31.5	36	0	1380	3000	3710
40	19	26.6	31.5	36	0	780	2124	2904

TABLE A2 Temperature and Pressure
Requirements for Operation of
Test at 95 F


	Air Pressure, psi			
	12	14	16	18
Temperature, deg F	114	117	119	121

	Air Pressure, kN/m ²			
	83	96	110	124
Temperature, deg C	46	47	48	49



- θ — Angle of lid, 90 to 125 deg
 1 — Thermometer and thermostat for controlling heater (Item No. 8) in base
 2 — Automatic water levelling device
 3 — Humidifying tower
 4 — Automatic temperature regulator for controlling heater (Item No. 5)
 5 — Immersion heater, non-rusting
 6 — Air inlet, multiple openings
 7 — Air tube to spray nozzle
 8 — Strip heater in base
 9 — Hinged top, hydraulically operated, or counterbalanced
 10 — Brackets for rods supporting specimens, or test table
 11 — Internal reservoir
 12 — Spray nozzle above reservoir, suitably designed, located, and baffled
 12A — Spray nozzle housed in dispersion tower located preferably in center of cabinet
 13 — Water Seal
 14 — Combination drain and exhaust. Exhaust at opposite side of test space from spray nozzle (Item 12), but preferably in combination with drain, waste trap, and forced draft waste pipe (Items 16, 17, and 19).
 16 — Complete separation between forced draft waste pipe (Item 17) and combination drain and exhaust (Items 14 and 19) to avoid undesirable suction or back pressure.
 17 — Forced draft waste pipe.
 18 — Automatic levelling device for reservoir
 19 — Waste trap
 20 — Air space or water jacket
 21 — Test table or rack, well below roof area

FIG. A1 Typical Salt Spray Cabinet.



NOTE—The controls are the same, in general as for the laboratory cabinet (Fig. A1), but are sized to care for the larger cube. The chamber has the following features:

- (1) Heavy insulation,
 (2) Refrigeration door with drip rail, or pressure door with drip rail, inward-sloping sill,
 (3) Low-temperature auxiliary heater, and
 (4) Duck boards on floor, with floor sloped to combination drain and air exhaust.

FIG. A2 Walk-in Chamber, 1.5 by 2.4 m (5 by 8 ft) and Upward in Over-all Size.




FIG. A3 Typical Spray Nozzle.

By publication of this standard no position is taken with respect to the validity of any patent rights in connection therewith, and the American Society for Testing and Materials does not undertake to insure anyone utilizing the standard against liability for infringement of any Letters Patent nor assume any such liability.